



NOTES:

- (1) MAX. TRENCH DEPTH SHALL NOT EXCEED 54".
- (2) BOTH PRIMARY AND SECONDARY ELECTRICAL CONDUIT.
- (3) P = PRIMARY ; S = SECONDARY ELECTRICAL CONDUIT.



TRENCH DETAILS  
PRI. AND SEC. ELECT. CONDUIT

ELECTRICAL CONSTRUCTION STANDARD.

APPROVED

5/15/06

ECS 100101  
3 of 3